

Hi everyone,

We will need to have an additional addendum prior to bids being received, but informally please be advised of the following:

- The new wear layer of asphalt is to be 1 1/2" thick in lieu of 1" thick. Please list the premium cost vrs. 1" as a voluntary alternate on your bid form.
- The new north side sidewalk is required to be 5 ft. wide and extended to the street by the City of Indianapolis. This will be addressed in a revised sketch to work with sloping grades.

Jim

James P. Mack, R.A.

President

Mack Architects, P.C.

5920 N. Keystone Avenue

Indianapolis, Indiana 46220

Office: (317) 251-2468

Fax: (317) 251-2469